



Paper Screenings Handling for Welsh Water

Technical Data		Plant Description
Infeed hopper	- 1100 x 1100 (1.5m ³) Mounted on loadcells	Paper screening from a WWTW sewage processing plant is delivered in big-bags having a flat bottom which is slit with a knife and fed in to a hopper. Discharge is by a multi-worm discharger with a screw feeder having variable speed to feed between 30-150kg per hour based on a bulk density of 300kg/m. ³
Screw discharger	- Ø250 x 1100 long Quadruple ribbon bladed	
Screw feeder	- Ø120 x 1800 long Variable speed	

Cleeve Materials Handling Limited

Suite 4, Prospect House, Bath Road Trading Estate, Stroud, Glos. GL5 3QF, UK



01453 750085



info@cleevemh.co.uk



http://cleevemh.co.uk